

OFFICE NAME	ADDRESS	PROVINCE	FLOOR LEVEL	GENERATOR LOCATION	Number of PC's /plugs to be connected to the Generator	Number of lights to connected to the Generator	ESTIMATED DISTANCE (IN METERS FROM GENERATOR TO UPS)
Johannesburg	2nd Floor, Lunga House, 124 Marshall Street, Marshalltown, Johannesburg	Gauteng	2 nd	Ground	25	8	Please make provision of 40m, subject to full measurement on site. Also note that the amount quoted for this item is to be used in part or in full at the discretion of the client (GPAA)
Durban	407 Anton Lembede Street, Salmon Grove Chambers, Durban	KZN	8th	Ground	30	10	
Pietermaritzburg	Brasfort House, 262 Langalibalele Street, Pietermaritzburg	KZN	3rd	Ground	35	18	
Port Elizabeth	Kwantu Towers, Sivuyile Mini-Square, Port Elizabeth	Eastern Cape	Ground	Ground	20	15	
Mthatha	Madeira Plaza, Cnr Elliot & Madeira Street, Mthatha	Eastern Cape	Ground	Ground	22	15	
Kimberley	11 Old Main Road, Kimberley	Northern Cape	Ground	Ground	30	10	
Mafikeng	Office 4/17 Mega City, Mafikeng	North West	Ground	Ground	30	12	

1. The thickness of the cable must be **16mm x 3core armoured cable.**
2. The thickness of the Bare Copper earth wire must be **10mm bare copper earth wire.**