



BLOCK H

1ST FLOOR PLAN SCALE 1 : 100

AC SPECIFICATIONS:

	24,000 BTU INVERTER HEAT PUMP CASSETTE UNIT
	18,000 BTU INVERTER HEAT PUMP CASSETTE UNIT
	18,000 BTU INVERTER HEAT PUMP CASSETTE UNIT 7.5KW
	36,000 BTU INVERTER HEAT PUMP CASSETTE UNIT
	WINDOW MOUNTED FAN: STYLEVENT HV230

- NOTES:
- CONDENSORS TO BE MOUNTED ON GROUND LEVEL ON EXTERIOR WALL ON CANTILEVERS
 - PIPES BETWEEN INTERIOR & EXTERIOR ON CABLE TRAY OR IN TRUNKING
 - OPEN PLAN UNITS MUST HAVE GROUP CONTROL WITH 1 THERMOSTAT INSIDE OFFICE
 - ELECTRICAL POINT TO EACH OUTDOOR UNIT BY ELECTRICIAN
 - ALL UNITS WITH CONDENSATE REMOVAL PUMPS

KEY TO SYMBOLS:		FLOOR FINISHES:		WALL FINISHES:		GENERAL NOTES:		
	EXISTING BRICK WALLS		EXIST 3-CHANNEL P/SKIRTING TO BE REMOVED		MERANTI DADO RAIL STAINED MAHOGANY, INSTALLED 850mm AFFL	PLEASE TAKE NOTE THAT THESE PLANS MUST BE READ IN CONJUNCTION WITH THE GPAA TENDER DOCUMENT	CONTRACTORS AND SUB-CONTRACTORS ARE TO CHECK ALL DIMENSIONS AND LEVELS ON SITE BEFORE COMMENCING WITH WORK OR CUTTING OF MATERIALS	
	EXISTING PARTITION WALLS		EXIST 3-CHANNEL P/SKIRTING INSTALLED AT GROUND LEVEL		PLASCRON CASHMERE INTERIOR ABOVE RAIL - IVORY WHITE Y4-B2-3			WRITTEN DIMENSIONS TAKE PREFERENCE OVER SCALED DIMENSIONS
	NEW DRY WALL UP TO CEILING HEIGHT OF 2600mm		NEW ISOLATOR		PLASCRON CASHMERE INTERIOR IVORY WHITE Y4-B2-3	THIS DRAWING IS THE COPYRIGHT OF GPAA AND MAY NOT BE USED FOR ANY PURPOSE WHATSOEVER WITHOUT WRITTEN APPROVAL FROM GPAA	ALL WORK TO COMPLY WITH THE BUILDING REGULATIONS SANS 10400 AND APPROVED MUNICIPAL BYLAWS	
	EXISTING WALLS TO BE DEMOLISHED		POP-UP IN DESK CONSISTS OF: 2 X NORMAL (WHITE) PLUGS 2 X DEDICATED (RED) PLUGS 1 X DATA POINT 1 X 2-PIN EURO PLUG		CERAMIC WALL TILES 600 X 600 SEE DETAIL LAYOUTS			<p>HR - PROPOSED NEW LAYOUT</p>
	RE-INSTALL EXISTING STANDARD HEIGHT DOOR 2000 IN ALU FRAME		DATA POINT		25mm PERFORATED NATURAL ALUMINIUM VENETIAN BLIND	<p>Department: Government Pensions Administration Agency REPUBLIC OF SOUTH AFRICA</p> <p>Project: BLOCK H 1ST FLOOR HR NEW LAYOUT</p> <p>Drawing Title: NEW AC LAYOUT</p>		
	NEW GLASS & ALU DOUBLE DOOR 2600mm IN ALU FRAME WITH H/DUTY DOOR CLOSER		BIOMETRIC READER	<p>NOTES: EXISTING WINDOW FRAMES TO BE PAINTED WHITE. INSIDE AND OUTSIDE</p>				Date:
	NEW WINDOW IN ALU FRAME 2000H X 600W WITH 600mm HIGH VINYL STRIP		WINDOW MOUNTED FAN			2013/12/23	SR	1:100 ON A1
			NEW WINDOW IN ALU FRAME 2175W WITH 600mm HIGH VINYL STRIP			Project Number:	Rev no:	Drawing Number:
			DOUBLE SWITCH SOCKET 16 AMP			GPAA-15	1	04-01
			SINGLE SWITCH SOCKET 16 AMP					
			SINGLE SWITCH SOCKET 16 AMP INSTALLED IN CEILING VOID					
			SINGLE RED DEDICATED SWITCH SOCKET 16 AMP					
			DOUBLE RED DEDICATED SWITCH SOCKET 16 AMP					
			SINGLE RED DEDICATED SWITCH SOCKET 16 AMP INSTALLED IN CEILING VOID					

HR - PROPOSED NEW LAYOUT

Department: Government Pensions Administration Agency
 REPUBLIC OF SOUTH AFRICA

Project: **BLOCK H
1ST FLOOR
HR NEW LAYOUT**

Drawing Title: **NEW AC LAYOUT**

Date:	Drawn by:	Scale:
2013/12/23	SR	1:100 ON A1
Project Number:	Rev no:	Drawing Number:
GPAA-15	1	04-01